

MUTHU. S. B.E., M.Sc., (Structs) F.I.E.,
F.I.V., F.I.I.R.A., I.I.T.A.,

Chartered Engineer Regn. No. : F-0172533
Registered Architect Regn. No. : CA/75/1479
Valuer of Wealth Tax & Income Tax
Government of India, Regn.No.C1/64 of 1988
Panel Valuer of L.I.C. of India

Associate :
Er. M. Ashokkumar B.E., M.E., M.I.E., F.I.V.,

Office : 37, North Veli Street,
MADURAI-625 001.
Phone : 0452-2340744
Cell : 98421-70744
E-mail : ermuthusivam@gmail.com

Residence : 24/13, Dr. Thangaraj Salai,
Vinayaga Nagar, Madurai-20.
Phone : 0452-2529021

STATEMENT ACCOMPANYING FORM

1. Door No. of the Building : Sury.No.3(P), 8(P) & 14/1B at Ayamthampatti Village, Alagar Koil, Valayapatty Panchayat, Alagar Koil, Melur Taluk, Madurai District.
2. Location : Street/Ward No. : M/s.MAHATMA MONTESSORI SCHOOL
Name of the Place,i.e., Corporation/
Municipality/Panchayat Union/
Town ship/Contonment : Sury.No.3(P),8(P) & 14/1B at
Ayamthampatti Village, Alagar Koil,
Valayapatty Panchayat, Melur Taluk and
Madurai District.
3. Year of construction : Northern Block : G.F.--1995, F.F. : 2002.
Southern Block - G.F. & F.F. : 2011.
Auditorium : 2011.
4. Approximate cost of construction as per Current rates : Rs.4 Crores/=
5. Purpose for which the building is being used or proposed to be used : EDUCATION.
6. Purpose for which the building has in Hitherto been used. : EDUCATION.
7. Details of construction of the building (Particulars of the foundation soil, Specification of the Various parts under).
 - a) Foundation : Partly R.R. Masonry in Cement and Partly R.C.C. footing foundation.
 - b) Basement : Partly R.R.Masonry and Partly Brick work in Cement along with R.C.C.Pillar.
 - c) Superstructures : Brick work in Cement.
 - d) Floor and roof are to be given : Partly Marble, Partly Cuddappa Stone, Partly Cement flooring, R.C.C. Roofing for Main Buildings. Cement flooring and Galvalium sheet roofing for Auditorium.
- 8.Period for which the license is required : 01.02.2023 to 31.01.2026 (3 years).
- 9.No.of persons to be accommodated : 500 Nos.

9.(a) "CERTIFIED" that no addition or alteration has been made to the existing or portion of a building for which this application has been made, I undertake to obtain a fresh license in case any addition or alteration is made to the existing or portion of building, I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of building or a portion of the building originally is changed or altered subsequently'.

SIGNATURE OF THE ENGINEER.

MUTHU. S., B.E., M.Sc., (Structs),
F.I.E., F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer & Registered Architect
Valuer of Wealth Tax and Income Tax
Government of India
37, North Veli Street, Madurai - 625 001.
Cell : 98421 70744

M. S. B.E., M.Sc., (Structs) F.I.E.,
F.I.V., F.I.I.R.A., I.I.T.A.,

Chartered Engineer Regn. No. : F-0172533
Registered Architect Regn. No. : CA/75/1479
Valuer of Wealth Tax & Income Tax
Government of India, Regn.No.C1/64 of 1988
Panel Valuer of L.I.C. of India

Associate :
Er. M. Ashokkumar B.E., M.E., M.I.E., F.I.V.,

Office : 37, North Veli Street,
MADURAI-625 001.
Phone : 0452-2340744
Cell : 98421-70744
E-mail : ermuthusivam@gmail.com

Residence : 24/13, Dr. Thangaraj Salai,
Vinayaga Nagar, Madurai-20.
Phone : 0452-2529021

"FORM-B"

FORM of Certificate of structural soundness under sub-section 4 of the Tamilnadu Public building (Licencing) Act 1965 (Tamilnadu Public Buildings (Licencing) Rules 1966.

I Certify that I have inspected the building mentioned in the Statement and furnished below the salient technical features.

1. FOUNDATION:

- a) Depth below ground level : 6'0" or 1.80 M. for R.C.C. footing foundation. 4'0" or 1.22 M. for R.R. Masonry foundation.
- b) Nature of soil met with at foundation : Gravel.
- c) Pressure at foundation : **Northern Block :**
For R.R. Masonry 20.12 M.T./Sqm.
For R.C.C. footing 44.48 M.T./Sqm.
Southern Block 28.32 M.T./Sqm.
Auditorium 11.85 M.T./Sqm.
- d) Probable safe bearing capacity of the Strata met with foundation : 45 M.T./Sqm.

2. SUPERSTRUCTURES:

- a) Maximum stress in the most critical : **Northern Block :**
Brick work in Cement 65.73 M.T./Sqm. for R.R.Masonry foundation and 5.86 M.T./Sqm. for R.C.C. footing foundation.
Brick work in Cement for Southern Block 5.18 M.T./Sqm.
- b) Nature of masonry and concrete and its safe permissible stress : Brick work in Cement 87 M.T./Sqm.
: R.R.Masonry in Cement 87 M.T./Sqm.
Cement Concrete 109 M.T./Sqm.

The Structural soundness of the building has been verified by me with reference to ISI loading Standard 875 (Latest version) and other relevant is code of practice and I declare that the Building is structurally sound to be used as public building for the purpose noted in the Statement. A Licence may be granted for the period from 01.02.2023 to 31.01.2026 (3 years) inclusive.


SIGNATURE OF THE ENGINEER.
MUTHU.S., B.E., M.Sc., (Structs)-,
F.I.E., F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer & Registered Architect
Valuer of Wealth Tax and Income Tax
Government of India
37, North Veli Street, Madurai - 625 001.
Cell : 98421 70744

S. B.E., M.Sc., (Structs) F.I.E.,
F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer Regn. No. : F-0172533
Registered Architect Regn. No. : CA/75/1479
Valuer of Wealth Tax & Income Tax
Government of India, Regn.No.C1/64 of 1988
Panel Valuer of L.I.C. of India

Office : 37, North Veli Street,
MADURAI-625 001.
Phone : 0452-2340744
Cell : 98421-70744
E-mail : ermuthusivam@gmail.com

Associate :
Er. M. Ashokkumar B.E., M.E., M.I.E., F.I.V.,

Residence : 24/13, Dr. Thangaraj Salai,
Vinayaga Nagar, Madurai-20.
Phone : 0452-2529021

DECLARATION

I.S.MUTHU, Son of Sevan. residing at 13,Dr.Thangaraj Salai,22,C,Vinayaga Nagar, Madurai-20 (Residence), 37, North Veli Street, Madurai-01 (Office) do hereby declare that I possess the Qualification and experience specified in the Table to Rule II of the Tamilnadu Public Buildings(Licensing) Rules 1966 for issuing of the Certificate of Structural soundness of the buildings covered by the certificate.


SIGNATURE OF THE ENGINEER,
MUTHU.S., B.E., M.Sc., (Structs),
F.I.E., F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer & Registered Architect
Valuer of Wealth Tax and Income Tax
Government of India
37, North Veli Street, Madurai - 625 001.
Cell : 98421 70744

1. Name & Address : S.MUTHU .B.E. M.Sc.(Structural),F.I.E., F.I.V.,
F.I.I.R.A, I.I.T.A.,37,North Veli Street, Madurai-625001.
2. Engineering Qualification : Degree holder in Bachelor of Engineering (Madras University) 1964 B.E., M.Sc.(Structural Engineering) Madras University-1966. Member in the Institutions of Chartered Engineers and Institution of Valuers and Registered Indian Architects & Arbitrator.
3. No. of years of Experience there of & Nature : 50 Years of Experience in Chartered Engineering and consulting Architects. Valuer of Wealth Tax and Income Tax Govt. of India, Panel Valuer of L.I.C. of India.


SIGNATURE OF THE ENGINEER,
MUTHU.S., B.E., M.Sc., (Structs),
F.I.E., F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer & Registered Architect
Valuer of Wealth Tax and income Tax
Government of India
37, North Veli Street, Madurai - 625 001.
Cell : 98421 70744

S. B.E., M.Sc., (Structs) F.I.E.,
F.I.V., F.I.I.R.A., I.I.T.A.,

Chartered Engineer Regn. No. : F-0172533
Registered Architect Regn. No. : CA/75/1479
Valuer of Wealth Tax & Income Tax
Government of India, Regn.No.C1/64 of 1988
Panel Valuer of L.I.C. of India

Associate :
Er. M. Ashokkumar B.E., M.E., M.I.E., F.I.V.,


Office : 37, North Veli Street,
MADURAI-625 001.
Phone : 0452-2340744
Cell : 98421-70744
E-mail : ermuthusivam@gmail.com

Residence : 24/13, Dr. Thangaraj Salai,
Vinayaga Nagar, Madurai-20.
Phone : 0452-2529021

FORM --'C'


FORM of opinion under Sub-section I of Section 5 of the Tamilnadu Public building (Licencing) Act 1965 (Tamilnadu XIII of 1965) referred to in Rule 5 of the Tamil Nadu public buildings (Licencing) Rules 1966.

I have inspected the building specified in the statement below, and I have satisfied myself that the building is structurally sound to be used as a public buildings, for the Purposed noted in the statement, the structural-soundness of the building has been verified, taking into account, the Loading as per the latest Indian standards 875, I am therefore of the opinion, that a licence may be granted for the Period 01.02.2023 to 31.01.2026 (3 years) inclusive.


SIGNATURE OF THE ENGINEER
MUTHU.S., B.E., M.Sc., (Structs).,
F.I.E., F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer & Registered Architect
Valuer of Wealth Tax and Income Tax
Government of India

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, Door. No., Street, and Name of the Place.	M/S.MAHATMA MONTESSORI SCHOOL in Sury.No.3(P), 8(P) & 14/1B at Ayathuampatti Village, Alagar Koil, Valayapatty Panchayat, Melur Taluk and Madurai District.
No. & age of the building. Northern Block-G.F. : 1995 -27 years, F.F. : 2002 - 20 years. Southern Block-2011 : 11 years. Auditorium-2011-11 years.	
Short description of the Structures.	Partly Load bearing walls, Partly R.C.C. Framed Structure, Brick Masonry walls, Partly Marble, Partly Cuddappa Stone, Partly Cement flooring. Galvalium Sheet roofing and Cement flooring for Auditorium.
Purpose for which the buildings is Certified for use.	EDUCATION.
Period for which the building will be structurally sound.	01.02.2023 to 31.01.2026 (3 years).
No. of persons to be accommodated.	500 Nos.
REMARKS : BUILDING IS STRUCTURALLY SAFE AND SOUND. STABILITY SHOULD BE CHECKED UP ONCE IN EVERY THREE YEARS.	


SIGNATURE OF THE ENGINEER.
MUTHU.S., B.E., M.Sc., (Structs).,
F.I.E., F.I.V., F.I.I.R.A., I.I.T.A.,
Chartered Engineer & Registered Architect
Valuer of Wealth Tax and Income Tax
Government of India
37, North Veli Street, Madurai - 625 001.
Cell : 98421 70744